

DEPARTMENT OF TRANSPORTATION

DIVISION OF ENGINEERING SERVICES

OFFICE ENGINEER

1727 30th Street MS-43

P.O. BOX 168041

SACRAMENTO, CA 95816-8041

FAX (916) 227-6214

www.dot.ca.gov/hq/esc/oe



*Serious Drought.
Help save water!*

December 21, 2015

01-Hum-299-R10.5/R10.7, R25.8/R26.1

01-0B4504

Project ID 0112000130

ACNH-ER-19C2(004)E

Addendum No. 1

Dear Contractor:

This addendum is being issued to the contract for CONSTRUCTION ON STATE HIGHWAY IN HUMBOLDT COUNTY NEAR BLUE LAKE FROM 0.5 MILE WEST TO 0.3 MILE WEST OF NORTH FORK MAD RIVER BRIDGE AND FROM 1.9 MILES WEST TO 1.3 MILES WEST OF OLD THREE CREEKS ROAD to revise the project plans, the *Notice to Bidders and Special Provisions, Information Handout*, and the Federal Minimum Wages with Modification Number 14 dated 12/11/2015.

Submit bids for this work with the understanding and full consideration of this addendum. The revisions declared in this addendum are an essential part of the contract.

Bids for this work will be opened on Tuesday, January 5, 2016.

On project plan sheet 1 (Title Sheet) each instance of "02" in the title block at the upper right of the plan sheet is replaced with "01".

On project plan sheet 16 (Q-1), "Temporary Concrete Washout" column in the Storm water Pollution Prevention table is deleted.

On project plan sheet 16 (Q-1), each instance of " " in the units row of the Rock Slope Protection (No. 1, Method B)(CY) column in the Roadway Quantities table is replaced with "CY".

On project plans sheet 16 (Q-1), each instance of "Temporary Reinforced Silt Fence (Type 1)" in the Storm water Pollution Prevention table is replaced with "Temporary Reinforced Silt Fence (Type 2)".

In the Special Provisions, Section 9, "PAYMENT," the following item is added to the list.

4. 24" Corrugated Steel Pipe (.109" thick)."

In the Special Provisions, Section 39-3.01D is added as follows:

"Replace the requirement in the row for "Voids in mineral aggregate on plant produced HMA" in the 2nd table in section 39-3.01D(5)(a) of the RSS for section 39 with:

18.0-23.0."

01-Hum-299-R10.5/R10.7, R25.8/R26.1
01-0B4504
Project ID 0112000130
ACNH-ER-19C2(004)E

In the Special Provisions, Section 39-3.02B is added as follows:

Replace the row for "Hamburg wheel track" in the table in section 39-3.02B of the RSS for section 39 with:

"

Hamburg wheel track (min number of passes at the inflection point)	AASHTO T 324 (Modified) ^d	
Binder grade:		
PG 58		10,000
PG 64		12,500
PG 70		15,000

"

On the Information Handout cover sheet, each instance of "R23.8/26.1" is replaced with "R25.8/R26.1".

To *Bid* book holders:

Inquiries or questions in regard to this addendum must be communicated as a bidder inquiry and must be made as noted in the *Notice to Bidders* section of the *Notice to Bidders and Special Provisions*.

Submit the *Bid* book as described in the *Electronic Bidding Guide* at the Bidders' Exchange website.

http://www.dot.ca.gov/hq/esc/oe/electronic_bidding/electronic_bidding.html

Inform subcontractors and suppliers as necessary.

This addendum, EBS addendum file and the modified wage rates are available for the Contractors' download on the Web site:

http://www.dot.ca.gov/hq/esc/oe/project_ads_addenda/01/01-0B4504

If you are not a *Bid* book holder, but request a book to bid on this project, you must comply with the requirements of this letter before submitting your bid.

Sincerely,


se CHARLIE FIELDER
District Director