

**DEPARTMENT OF TRANSPORTATION**

DIVISION OF ENGINEERING SERVICES

OFFICE ENGINEER

1727 30<sup>th</sup> Street MS-43

P.O. BOX 168041

SACRAMENTO, CA 95816-8041

FAX (916) 227-6214

www.dot.ca.gov/hq/esc/oe



*Serious Drought.  
Help save water!*

January 22, 2015

05-SB-246-12.3/R16.7

05-OC6404

Project ID 0500000021

Addendum No. 4

Dear Contractor:

This addendum is being issued to the contract for CONSTRUCTION ON STATE HIGHWAY IN SANTA BARBARA COUNTY NEAR LOMPOC FROM CEBADA CANYON ROAD TO HAPGOOD ROAD (EAST).

Submit bids for this work with the understanding and full consideration of this addendum. The revisions declared in this addendum are an essential part of the contract.

Bids for this work will be opened on Thursday, January 29, 2015.

This addendum is being issued to revise the *Notice to Bidders and Special Provisions*.

In the Special Provisions, Section 39-1.02H(1), is added as attached.

In the Special Provisions, Section 68, is added as attached.

In the Special Provisions, Section 88-1.02B, is replaced as follows:

**"Add to section 88-1.02B:**

Filter fabric for permeable material blanket must be Class B."

Addendum No. 4  
Page 2  
January 22, 2015

05-SB-246-12.3/R16.7  
05-0C6404  
Project ID 0500000021

To *Bid* book holders:

Inquiries or questions in regard to this addendum must be communicated as a bidder inquiry and must be made as noted in the *Notice to Bidders* section of the *Notice to Bidders and Special Provisions*.

Submit the *Bid* book as described in the *Electronic Bidding Guide* at the Bidders' Exchange website.

**[http://www.dot.ca.gov/hq/esc/oe/electronic\\_bidding/electronic\\_bidding.html](http://www.dot.ca.gov/hq/esc/oe/electronic_bidding/electronic_bidding.html)**

Inform subcontractors and suppliers as necessary.

This addendum, EBS addendum file, attachments and the modified wage rates are available for the Contractors' download on the Web site:

**[http://www.dot.ca.gov/hq/esc/oe/project\\_ads\\_addenda/05/05-0C6404](http://www.dot.ca.gov/hq/esc/oe/project_ads_addenda/05/05-0C6404)**

If you are not a *Bid* book holder, but request a book to bid on this project, you must comply with the requirements of this letter before submitting your bid.

Sincerely,



SHARRI BENDER EHLERT  
District Director  
District 6 Central Region

Attachments

**Delete the 3rd paragraph in section 39-1.02H(1) of the RSS for section 39.**

## **68 SUBSURFACE DRAINS**

**Replace section 68-5 with:**

### **68-5 PERMEABLE MATERIAL BLANKET**

#### **68-5.01 GENERAL**

Section 68-5 includes specifications for installing permeable material blankets.

#### **68-5.02 MATERIALS**

Permeable material for permeable material blanket must be Class 1 (Type B) and must comply with section 68-2 except for payment.

Filter fabric must comply with section 88-1.02B.

#### **68-5.03 CONSTRUCTION**

Place filter fabric as follows:

1. Ensure the subgrade complies with the compaction and elevation tolerance specified for the material involved before placing the filter fabric on the subgrade.
2. Handle and place filter fabric under the manufacturer's instructions.
3. Align and place the fabric without wrinkles.
4. Overlap or stitch adjacent borders of the fabric from 12 to 18 inches. The preceding roll must overlap the following roll in the direction the permeable material is being spread or must be stitched. If the fabric is joined by stitching, the fabric must be stitched with yarn of a contrasting color. The size and composition of the yarn must be as recommended by the fabric's manufacturer. The stitches must number 5 to 7 per 1 inch of seam.
5. Cover the fabric with the planned thickness of permeable material or aggregate subbase material as shown within 24 hours after the filter fabric has been placed.
6. Maintain a minimum of 6 inches of the material between the fabric and your equipment during spreading and compaction of the permeable material and aggregate subbase. Where embankment material is to be placed on the filter fabric, maintain a minimum of 18 inches of embankment material between the fabric and your equipment. Do not operate or drive equipment or vehicles directly on the filter fabric.

#### **68-5.04 PAYMENT**

Permeable material (blanket) is measured by the dimensions shown.